



City of Deltona

2345 Providence Blvd.
Deltona, FL 32725

Minutes - Final

Special Magistrate

Wednesday, September 24, 2025

5:30 PM

Deltona Commission Chambers

1. CALL TO ORDER:

The meeting was called to order at 5:37 pm.

2. ROLL CALL:

Special Magistrate Kristin Eick
Code Compliance Manager Danny Ron
Code Compliance Supervisor Mark Gibson
Code Compliance Supervisor Todd Meade
Hearing Clerk Jessica Cotterman
Code Admin. Supervisor Renée Cairney
Officer Enrique Rios
Officer Janice Polascik
Officer Jeff Scott
Captain/Assistant Fire Marshal Samuel Schaller
Fire Inspector Lisa Nadeau

3. PLEDGE TO THE FLAG:

4. SPECIAL MAGISTRATE STATEMENT:

Ms. Eick has taken a Judicial Notice of all City of Deltona Ordinances, State Statues, Florida Building and Fire Codes and the International Property Maintenance Code.

5. DISCLOSURE OF EX PARTE COMMUNICATIONS:

None

6. APPROVAL OF AGENDA & MINUTES:

The Minutes of the Special Magistrate hearing for August 27, 2025 were approved by the Special Magistrate Kristin Eick.

7. ANNOUNCEMENTS:

Withdrawn Cases:

FIRE-027-2025 - 271 Fort Smith Boulevard - In Compliance September 18, 2025
FIRE-037-2025 - 1200 Deltona Boulevard - In Compliance

DEL-25-037 (B) Massey - 960 Shorecrest Avenue - In Compliance September 24, 2025

Continued Cases:

DEL-25-086 - 679 Vicksburg Street

DEL-25-089 - 1556 E. Normandy Boulevard

8. SWEARING IN OF OFFICERS AND WITNESSES:

9. OLD BUSINESS:

DEL-25-037 Massey

Property Address:

960 Shorecrest Avenue, Deltona, FL 32725

Parcel ID: 8130-11-44-0180

Property Owner:

Diane Holm

P.O. Box 530846

Debary, FL 32753-0846

Violation:

City of Deltona Ordinance, Section 18-5, adopting the latest edition of the International Property Maintenance Code, Section 304.6, which states that all exterior walls shall be free from holes, breaks, and loose or rotting materials; and maintained weatherproof and properly surface coated where required to prevent deterioration.

Corrective action:

Repair the exterior walls, facia, and soffits and painted with a proper treatment..

Officer Bashir Tourkzi

The case was brought into compliance and withdrawn.

DEL-25-054 (A-C) Massey

Property Address:

916 Shorecrest Avenue, Deltona, FL 32725

Parcel ID: 8130-11-41-0180

Property Owner:

Shamra R Taylor

916 Shorecrest Avenue

Deltona, FL 32725**Violation: A**

City of Deltona Ordinance, Section 18-3, adopting the latest edition of the Florida Building Code, Section 105.1, which states that any owner, authorized agent, who intends to construct, enlarge, alter, repair, move, demolish, or change the occupancy of a building or structure, or to erect, install, enlarge, alter, repair, remove, convert or replace any electrical, gas, mechanical or plumbing system, the installation of which is regulated by this code, or to cause any such work to be done, shall first make application to the Building Official and obtain the required permit.

Corrective action:

You must obtain a permit for the (Accessory Structure /Shed). Applications must be submitted to the City of Deltona, 2345 Providence Boulevard, Deltona, FL 32725. The structure must meet all requirements of city ordinance and be approved on final inspection. Contact our office with the permit number when obtained.

Violation: B

City of Deltona Ordinance, , Section 18-3, adopting the latest edition of the Florida Building Code, Section 105.1, which states that any owner, authorized agent, who intends to construct, enlarge, alter, repair, move, demolish, or change the occupancy of a building or structure, or to erect, install, enlarge, alter, repair, remove, convert or replace any electrical, gas, mechanical or plumbing system, the installation of which is regulated by this code, or to cause any such work to be done, shall first make application to the Building Official and obtain the required permit.

Corrective action:

You must obtain a permit for the accessory structure (Pergola). Applications must be submitted to the City of Deltona, 2345 Providence Boulevard, Deltona, FL 32725. The structure must meet all requirements of city ordinance and be approved on final inspection. Contact our office with the permit number when obtained.

Violation: C

City of Deltona Ordinance, Section 18-3, adopting the latest edition of the Florida Building Code, Section 105.1, which states that any owner, authorized agent, who intends to construct, enlarge, alter, repair, move, demolish, or change the occupancy of a building or structure, or to erect, install, enlarge, alter, repair, remove, convert or replace any electrical, gas, mechanical or plumbing system, the installation of which is regulated by this code, or to cause any such work to be done, shall first make application to the Building Official and obtain the required permit.

Corrective action:

You must obtain a permit for the concrete flatwork (concrete drive behind the fence and slab for Acc. Structure/ Shed). Applications must be submitted to the City of Deltona, 2345 Providence Boulevard, Deltona, FL 32725. The structure must meet all requirements of city ordinance and be approved on final inspection. Contact our office with the permit number when obtained.

Officer Bashir Tourkzi

The Magistrate found the Respondent did not correct the violations within the time specified in the prior Order. A fine in the amount of \$4,350, representing 29 days at (\$50 per violation) \$150 per day (consistent with prior Order) is imposed. The fine will continue to accrue for each and every day thereafter that there continues to be non-compliance with the City Code. Property owner Shamra Taylor and Michael Berry were present to testify.

DEL-25-066 Massey

Property Address:

3259 Shingler Terrace, Deltona, FL 32738

Parcel ID: 8130-47-02-0240

Property Owner:

Vivian Jimenez

3259 Shingler Terrace

Deltona, FL 32738

Violation:

City of Deltona Ordinance, Section 18- 5, which adopts the latest edition of the International Property Maintenance Code, Section 304.7, which states the roof and flashing shall be sound, tight and not to have defects that admit rain.

Corrective action:
Repair or replace soffits.

Officer Janice Polascik

The Magistrate found the Respondent did not correct the violation within the time specified in the prior Order. A fine in the amount of \$850, representing 34 days at \$25 per day (consistent with prior Order) is imposed. The fine will continue to accrue for each and every day thereafter that there continues to be non-compliance with the City Code. Property owner was not present to testify.

FIRE-015-2025 Massey

Property Address:

1698 Diane Terrace, Deltona, FL 32725

Parcel ID: 8130-03-36-0200

Property Owner:

Harmony Clinic

1948 Saxon Boulevard

Deltona, FL 32725

Violation:

**City of Deltona Ordinance, Chapter 42, Article IV, Fire Codes, Ch.42-186-
Adopted Florida Fire Prevention Code 8th Edition**

**Violation - A NFPA 1, 18.2.3.5.1.1 – Fire apparatus access roads shall
have an unobstructed width of not less than 20 ft (6.1 m)**

**Violation – B NFPA 1, 18.2.3.5.1.2 - Fire Department access roads shall
have an unobstructed vertical clearance of not less than 13 ft 6 in. (4.1
m)**

**Violation – C NFPA 1, 18.2.3.5.1.2.2 - Vertical clearances shall be
increased when vertical clearances are not adequate to accommodate
fire apparatus.**

**Violation - D NFPA 1, 1.7.12.10 – No construction work shall proceed
until the AHJ has reviewed the plans for compliance with the applicable
codes and standards and the applicable permits have been issued.**

Corrective action:

Violation – A Please trim the trees at the entrance of the driveway and the parking lot to provide a minimum unobstructed width of no less than 20 ft.

Violation – B & C Please trim the trees at the entrance of the driveway and the parking lot to provide a minimum unobstructed vertical clearance of no less than 17 ft.

Violation – D Obtain a building permit for the following work:

1. Installation of the overhanging structure and concrete pad at the main entrance to the structure, located on the west side of the building.

2. Installation of the newly construction partition walls in each X-Ray Room.

3. Obtain a permit for the newly installed electric counter-top range.

4. Installation of the newly installed washer & dryer, and associated electrical, mechanical, and plumbing located inside of the closet

5. Removal of existing interior walls and construction of new interior walls.

6. Obtain a permit for the installation of the sink located inside of the laundry room and associated plumbing.

7. Obtain a permit for the replacement of the water heater.

8. Obtain a permit for the installation of the air conditioning unit installed inside of the physical therapy/newly converted X-Ray room.

Fire Safety Inspector Lisa Nadeau

The Magistrate found the Respondent did not correct Violation D within the time specified in the prior Order, Violations A-C were in compliance before prior Order was issued. A fine in the amount of \$1,450, representing 29 days at \$50 per day (consistent with prior Order) is imposed. The fine will continue to accrue for each and every day thereafter that there continues to be non-compliance with the City Code. Property owner Lester Correro was present to testify.

FIRE-027-25 Massey**Property Address:**

271 Fort Smith Boulevard, Deltona, FL 32738

Parcel ID: 8130-42-25-0150

Property Owner:

Two Star Investment Inc

271 Fort Smith Boulevard

Deltona, FL 32738Violation:City of Deltona Ordinance,

Violation A: Chapter 42, Article IV, Fire Codes, Ch. 42-186. – Adopted.
Florida Fire Prevention Code 8th Edition, NFPA 1, Ch. 1.7.12.10 - No
construction work shall proceed until the AHJ has reviewed the plans
for compliance with the applicable codes and standards and the
applicable permits have been issued.

Violation B: Chapter 42, Article IV, Fire Codes, Ch. 42-186. – Adopted.
Florida Fire Prevention Code 8th Edition, NFPA 1, Ch. 11.1.8 - All
panelboard and switchboards, pull boxes, junction boxes, switches,
receptacles, and conduit bodies shall be provided with covers
compatible with the box or conduit body construction and suitable for
the conditions of use.

Violation C: Chapter 42, Article IV, Fire Codes, Ch. 42-186. – Adopted.
Florida Fire Prevention Code 8th Edition, NFPA 1, Ch. 11.1.2.2.1 - Where
the AHJ determines that there is sufficient evidence that existing
electrical wiring, fixtures, appliances, or equipment is potentially
unsafe, the AHJ is authorized to require an evaluation of the existing
electrical wiring, fixtures, appliances, or equipment, or portion thereof,
by a qualified person.

Violation D: Chapter 42, Article IV, Fire Codes, Ch. 42-186. – Adopted.
Florida Fire Prevention Code 8th Edition, NFPA 1, Ch. 11.1.2.2 - Unless
determined to present an imminent danger, existing electrical wiring,
fixtures, appliances, and equipment shall be permitted to be maintained
in accordance with the edition of NFPA 70 in effect at the time of the
installation.

Violation E: Chapter 42, Article IV, Fire Codes, Ch. 42-186. – Adopted.
Florida Fire Prevention Code 8th Edition, NFPA 1, Ch. 11.1.7.3.1- Each
disconnecting means shall be legibly marked to indicate its purpose
unless located and arranged so the purpose is evident. In other than
one- or two-family dwellings, the marking shall include the identification
of the circuit source that supplies the disconnecting means. The
marking shall be of sufficient durability to withstand the environment

involved.

Corrective action:

Violation A: Obtain a permit for the installation of the new electrical panel and call in all final inspections.

Violation B: Provide an approved cover plate for the open junction box.

Violation C: Contact a licensed electrician to provide a report containing an assessment of the electrical wiring, fixtures, appliances, or equipment along with recommendations for any needed repairs to correct the unsafe condition(s).

Violation D: Junction box does not appear to provide adequate free space for enclosed conductors. Please install a secondary junction box & relocate excess wiring. All work shall be conducted by licensed electrician.

Fire Safety Inspector Ajorie Bailey

The case was brought into compliance and withdrawn.

10. NEW BUSINESS:

DEL-25-086 (A-C)

Property Address:

679 Vicksburg Street, Deltona, FL 32725

Parcel ID: 8130-04-38-0350

Property Owner:

Cesar Borges

Tamara Pita Pinheiro

679 Vicksburg Street

Deltona, FL 32725

Violation: A

City of Deltona Ordinance, Section 18-3, adopting the latest edition of the Florida Building Code, Section 105.1, which states that any owner, authorized agent, who intends to construct, enlarge, alter, repair, move, demolish, or change the occupancy of a building or structure, or to

erect, install, enlarge, alter, repair, remove, convert or replace any electrical, gas, mechanical or plumbing system, the installation of which is regulated by this code, or to cause any such work to be done, shall first make application to the Building Official and obtain the required permit.

Corrective action:

You must obtain a permit for (Accessory Structure Conversion into Apartments). Applications must be submitted to the City of Deltona, 2345 Providence Boulevard, Deltona, FL 32725. The structure must meet all requirements of city ordinance and be approved on final inspection. Contact our office with the permit number when obtained.

Violation: B

City of Deltona Ordinance, Section 18-3, adopting the latest edition of the Florida Building Code, Section 105.1, which states that any owner, authorized agent, who intends to construct, enlarge, alter, repair, move, demolish, or change the occupancy of a building or structure, or to erect, install, enlarge, alter, repair, remove, convert or replace any electrical, gas, mechanical or plumbing system, the installation of which is regulated by this code, or to cause any such work to be done, shall first make application to the Building Official and obtain the required permit.

Corrective action:

You must obtain a permit (ELECTRICAL) for the accessory structure. Applications must be submitted to the City of Deltona, 2345 Providence Boulevard, Deltona, FL 32725. The structure must meet all requirements of city ordinance and be approved on final inspection. Contact our office with the permit number when obtained.

Violation: C

City of Deltona Ordinance, Section 18-3, adopting the latest edition of the Florida Building Code, Section 105.1, which states that any owner, authorized agent, who intends to construct, enlarge, alter, repair, move, demolish, or change the occupancy of a building or structure, or to erect, install, enlarge, alter, repair, remove, convert or replace any electrical, gas, mechanical or plumbing system, the installation of which is regulated by this code, or to cause any such work to be done, shall

first make application to the Building Official and obtain the required permit.

Corrective action:

You must obtain a permit for (PLUMBING) in the accessory structure. Applications must be submitted to the City of Deltona, 2345 Providence Boulevard, Deltona, FL 32725. The structure must meet all requirements of city ordinance and be approved on final inspection. Contact our office with the permit number when obtained.

Officer Bashir Tourkzi

The case was continued to October by the City.

DEL-25-087 A & B

Property Address:

3182 Overdale Street, Deltona, FL 32738

Parcel ID: 8130-42-03-0150

Chase T & Megan Carr

3182 Overdale Street

Deltona, FL 32738

Violation: A

City of Deltona Ordinance, Section 18-5, adopting the latest edition of the International Property Maintenance Code, Section 302.7, which states accessory structures, including detached garages, fences and walls, shall be maintained structurally sound and in good repair.

Corrective Action:

Repair/install gate or remove the fence.

Violation: B

City of Deltona Ordinance, Section 66-18 (e), which states that no vehicles may be parked or stored in the front yard forward of the edge of the principal dwelling except on the approved driveway or driveway extension.

Corrective Action:

All vehicles parked in the front portion of the property must be on an approved driveway or driveway extension. Vehicles may also be

parked on the side of the house behind the front face or in the rear yard.
All vehicles must have a current tag and be operable, or they must be
stored in an enclosed garage.

Officer Enrique Rios

The case was continued to October by the City.

DEL-25-088

Property Address:

682 Deltona Boulevard, Deltona, FL 32725

Parcel ID: 8036-05-01-0030

Property Owner:

Multi Lynk Entertainment LLC

682 Deltona Boulevard

Deltona, FL 32725

Violation:

City of Deltona Ordinance, , Section 38-114, which states that storage of building materials, commercial and industrial equipment, materials, objects or waste relating to commercial or industrial uses, or any equipment, materials or objects that are not incidental to a residential use, shall be prohibited. Furniture outside must be designed to be placed outdoors or stored inside a covered structure. In addition, storage of materials relating to residential use, children's play toys, firewood, brush, logs or any other material intended to be used in fireplaces or other permitted burning facilities, shall be permitted only in the rear yard next to the rear wall of the home.

Corrective Action:

Remove outdoor storage (debris / materials) from the property.

Officer Jeff Scott

The case was dismissed by the Special Magistrate. Property owner Delford Blackburn was present to testify.

DEL-25-089

Property Address:

1556 E Normandy Boulevard, Deltona, FL 32725

Parcel ID: 8130-11-23-0020

Property Owner:

Debra S. McGee
1556 E Normandy Boulevard
Deltona, FL 32725

Violation:

City of Deltona Ordinance, Section 18-5 adopting the latest edition of the International Property Maintenance Code, Section 303.1, which states that swimming pools shall be maintained in a clean and sanitary condition, and good repair.

Corrective Action:

Pool must be maintained and either drained of water or water must be chemically treated to remove algae, water should be clear and sanitized.

Officer Jeff Scott

The case was continued to the October meeting by the City.

DEL-25-090 (A-C)

Property Address:

1018 Giovanni Street, Deltona, FL 32725

Parcel ID: 8130-07-45-0010

Property Owner:

Jose Yoihans Pereira Alvarez
1018 Giovanni Street
Deltona, FL 32725

Violation: A

City of Deltona Ordinance, SEC. 38-113 (a) - MAINTAIN ROW - which states it shall be the responsibility of every owner, agent or tenant of improved property in the city to, at all times, maintain those rights-of-ways most nearly abutting their property. These responsibilities shall include removing litter and debris, and cutting the grass and weeds to maintain a neat and trimmed appearance.

Corrective Action:

Removal of all litter and debris, and cutting the grass and weeds to maintain a neat and trimmed appearance. Where the grass has been worn out, replace with new sod and/or seed.

Violation: B

City of Deltona Ordinance, SEC. 58-31(a) - USE OF CITY RIGHTS OF WAY - which states that Consent required. Pursuant to the police power of the city, the city commission determines, in the interest of the health, safety and welfare of its citizens, that the use of any city right-of-way, including appendages, and the use of any public lands under the authority of the city commission, except for their intended purpose, without prior written consent of the city shall be prohibited.

Corrective Action:

Remove the object and obtain a permit, if available. (Driving through the right of way).

Violation: C

City of Deltona Ordinance, City of Deltona Ordinance, Section 110-807 (E) Storage of stock in trade (i.e. materials or supplies used in the home occupation) shall be located within the space limitations in Section 110-807 (D). No products shall be displayed on the premises. No toxic/hazardous materials shall be stored on the premises.

Corrective Action:

Remove all stock and commodities from the residential dwelling (all dumpsters).

Officer Jeff Scott

This case was continued to October by the City. Property owner Jose Pereira was present to testify.

FIRE-37-2025

Property Address:

1200 Deltona Boulevard, Deltona, FL 32727

Parcel ID: 8130-06-00-0020

Property Owner:

Deltona Wellness LP

P.O. Box 280

Lawrence, NY 11559-0280

Violation: A

City of Deltona Ordinance, Chapter 42, Article IV, Fire Codes, Ch.42-186

– Adopted Florida Fire Prevention Code 8th Edition, NFPA 1, CH.13.1.6 –
Detailed records documenting all systems and equipment testing and
maintenance shall be kept by the property owner and shall be made
available upon request for review by the AHJ.

Corrective Action:

Please provide a copy of the current backflow inspection/maintenance
report.

Violation: B

City of Deltona Ordinance, Chapter 42, Article IV, Fire Codes, Ch.42-186

– Adopted Florida Fire Prevention Code 8th Edition, NFPA 72,
CH.10.6.5.4 – Where a circuit breaker is the disconnecting means, an
approved breaker locking device shall be installed.

Corrective Action:

Please provide an approved breaker lock on breaker supplying the fire
alarm control panel.

Violation: C

City of Deltona Ordinance, Chapter 42, Article IV, Fire Codes, Ch.42-186

– Adopted Florida Fire Prevention Code 8th Edition, NFPA 1, CH.13.1.8 –
All fire protection systems and devices shall be maintained in a reliable
operating condition and shall be replaced or repaired where defective
or recalled.

Corrective Action:

Please contact your fire alarm service provider to correct the
deficiencies noted on the 05/23/2025 fire alarm inspection report.

Fire Safety Inspector Ajorie Bailey

This case was brought into compliance and withdrawn by the City.

FIRE-038-2025 (A-E)

Property Address:

605 Courtland Boulevard, Deltona, FL 32738

Parcel ID: 8136-03-00-0010

Property Owner:

MFP Deltona LLC

P.O. Box 126428
Hialeah, FL 33012

Violation: A

City of Deltona Ordinance, Chapter 42, Article IV, Fire Codes, Ch.42-186
– Adopted Florida Fire Prevention Code 8th Edition, NFPA 1, CH.13.1.6 –
Detailed records documenting all systems and equipment testing and
maintenance shall be kept by the property owner and shall be made
available upon request for review by the AHJ.

Corrective Action:

Please provide a copy of the current backflow inspection/maintenance
report

Violation: B

City of Deltona Ordinance, Chapter 42, Article IV, Fire Codes, Ch.42-186
– Adopted Florida Fire Prevention Code 8th Edition, NFPA 13, Ch
16.12.5.6– Where a fire department connection services only a portion
of a building, a sign shall be attached indicating the portions of the
building served. property owner and shall be made available upon
request for review by the AHJ.

Corrective Action:

Provide signage on the FDC indicating which portion of the building it
serves (IE. Retail).

Violation: C

City of Deltona Ordinance, Chapter 42, Article IV, Fire Codes, Ch.42-186
– Adopted Florida Fire Prevention Code 8th Edition, NFPA 1, 63.2.12.2.2
– Signs prohibiting or open flames within 25 ft (7.6m) of area perimeters
shall be provided in areas where toxic, highly toxic, corrosive, unstable
reactive, flammable, oxidizing, or pyrophoric gases are produced,
stored, or used.

Corrective Action:

Please provide signage on the LP Tank which states “NO SMOKING.”

Violation: D

City of Deltona Ordinance, Chapter 42, Article IV, Fire Codes, Ch.42-186

– Adopted Florida Fire Prevention Code 8th Edition, NFPA 1, 4.1.3.2.2.5 –
Buildings shall be designed and constructed to provide reasonable
signage and lighting to identify hazards, exits, means of egress, and
other building safety features.

Corrective Action:

Please provide room identification signage on the exterior of the door
that houses the fire sprinkler riser, which indicates “Fire Sprinkler Riser
Inside.” Please ensure sign is designed to withstand outdoor
conditions.

Violation: E

City of Deltona Ordinance, Chapter 42, Article IV, Fire Codes, Ch.42-186

– Adopted Florida Fire Prevention Code 8th Edition, NFPA 1, 13.1.8 – All
fire protection systems and devices shall be maintained in a reliable
operating condition and shall be replaced or repaired where defective
or recall.

Corrective Action:

Please contact your fire alarm service provider to repair the
deficiencies outlined in the 12/03/2024 fire alarm inspection report.

Fire Safety Inspector Lisa Nadeau

Special Magistrate found the Respondent in violation of the City Code as charged, for (Violations A & C) that the Respondent correct the violations no later than 4PM October 24, 2025 after this Order is entered in writing; that in the event the Respondent does not comply with the Order, a fine in the amount of \$50 per day/per violation for a total fine of \$100, will be imposed for each and every day the violations continue past the aforementioned date, that Respondent is further ordered to contact the Code Compliance Officer to verify compliance with this order. Property owner was not present to testify. Violations B & D were withdrawn by the City as they were in compliance prior to this hearing.

FIRE-039-2025

Property Address:

1878 Providence Boulevard, Deltona, FL 32725

Parcel ID: 8130-15-16-0060

Property Owner:

Fastlane 1878 Investments Inc

838 N Ridgewood Avenue

Daytona Beach, FL 32114-2040

Violation:

City of Deltona Ordinance, Chapter 42, Article IV, Fire Codes, Ch.42-186

– Adopted Florida Fire Prevention Code 8th Edition, NFPA 1,

Ch.1.7.12.10 – No construction work shall proceed until the AHJ has reviewed the plans for compliance with the applicable codes and standards and the applicable permits have been issued.

Corrective Action:

Obtain an issued building permit for the construction of the newly built wall and door.

Fire Safety Inspector Ajorie Bailey

The case was continued by the City to the October 22, 2025 hearing date.

FIRE-040-2025 A & B**Property Address:**

2772 Elkcam Boulevard, Deltona, FL 32738

Parcel ID: 8130-74-24-0310

Property Owner:

Family Home Plaza Partnership

1961 Evard Avenue

Deltona, FL 32725

Violation: A

City of Deltona Ordinance, Chapter 42, Article IV, Fire Codes, Ch.42-186

– Adopted Florida Fire Prevention Code 8th Edition, NFPA 1,

Ch.1.7.12.10 – No construction work shall proceed until the AHJ has reviewed the plans for compliance with the applicable codes and standards and the applicable permits have been issued.

Corrective Action:

Obtain permit for the installation of the new electrical wiring inside of the small closet or remove the wiring.

Violation: B

City of Deltona Ordinance, Chapter 42, Article IV, Fire Codes, Ch.42-186

– Adopted Florida Fire Prevention Code 8th Edition, NFPA 1,

Ch.1.7.12.10 No construction work shall proceed until the AHJ has

reviewed he plans for compliance with the applicable codes and standards and the permits have been issued.

Corrective Action:

Obtain permit for the installation of the magnetic locking system used at the front door or remove the magnetic locking system.

Fire Safety Inspector Lisa Nadeau

The case was continued by the City to the October 22, 2025 hearing date for Violation B. Violation A was withdrawn by the City as in compliance.

11. OTHER AND REPEAT BUSINESS:

None

13. ADJOURNMENT:

The meeting was adjourned at 7:20 pm.

Special Magistrate Kristin Eick

Hearing Clerk Jessica Cotterman