



Legislation Details

File #: 15-8850 **Version:** 1

Type: Code Violation **Status:** New Business

File created: 6/14/2024 **In control:** Special Magistrate

On agenda: 7/2/2024 **Final action:**

Title: FIRE-24-033

Property Address:
600 Fort Smith Blvd., Deltona, FL 32738
Parcel ID: 813400000042
Property Owner:
Florida District Church of Nazarene
4720 Cleveland Heights
Lakeland, FL 3813

Violation:

City of Deltona Ordinance, Chapter 42, Article IV, Fire Codes, Ch. 42-186. – Adopted.
Florida Fire Prevention Code 8th Edition, NFPA 1, Ch. 1.7.12.10 - No construction work shall proceed until the AHJ has reviewed the plans for compliance with the applicable codes and standards and the applicable permits have been issued, Ch. 11.1.5.6 - Extension cords shall be permitted to be used on portable appliances to the nearest receptacle where receptacle spacing is in accordance with NFPA 70.

Corrective Action:

Obtain building and electrical permits for the construction of the stage/platform, drum booth, walled off egress doors, newly installed exterior doors, sound booth and associated electrical and removal of illuminated exit sign. Obtain a permit for the demolition of the wall and door in the foyer/hallway area and relocated, demolished, and newly constructed walls and doors inside of the sanctuary, and obtain an electrical permit for the electrical work conducted on the exterior of the structure. Cease the permanent usage of the extension cords being used on the fence/front entrance area.

Captain / Assistant Fire Marshal Samuel Schaller

Sponsors:

Indexes:

Code sections:

Attachments:

| Date | Ver. | Action By | Action | Result |
|------|------|-----------|--------|--------|
|------|------|-----------|--------|--------|