



## Legislation Details

---

**File #:** 15-8849      **Version:** 1

**Type:** Code Violation      **Status:** New Business

**File created:** 6/14/2024      **In control:** Special Magistrate

**On agenda:** 7/2/2024      **Final action:**

**Title:** FIRE-24-032

Property Address:  
577 Deltona Blvd., Deltona, FL 32725  
Parcel ID: 803605090040  
Property Owner:  
Deltona Squear LLC  
259 E Rand Rd Apt 200  
Mount Prospect, IL 60056

**Violation:**

City of Deltona Ordinance, : Chapter 42, Article IV, Fire Codes, Ch. 42-186. – Adopted.  
Florida Fire Prevention Code 8th Edition, NFPA 1, Ch. 1.7.12.10 - No construction work shall proceed until the AHJ has reviewed the plans for compliance with the applicable codes and standards and the applicable permits have been issued, Ch. 11.1.7.3.1 - Each disconnecting means shall be legibly marked to indicate its purpose unless located and arranged so the purpose is evident. In other than one- or two-family dwellings, the marking shall include the identification of the circuit source that supplies the disconnecting means. The marking shall be of sufficient durability to withstand the environment involved.

**Corrective Action:**

Obtain a building and electrical permit for the removal of the interior walls and the construction of the new interior walls and installation of additional electrical receptacles.

Captain / Assistant Fire Marshal Samuel Schaller

**Sponsors:**

**Indexes:**

**Code sections:**

**Attachments:**

| Date | Ver. | Action By | Action | Result |
|------|------|-----------|--------|--------|
|------|------|-----------|--------|--------|