



Legislation Details

File #:	15-8851	Version:	1
Type:	Code Violation	Status:	New Business
File created:	6/14/2024	In control:	Special Magistrate
On agenda:	7/2/2024	Final action:	
Title:	FIRE-24-034 Property Address: 1240 Providence Blvd., STE 4, Deltona, FL 32725 Parcel ID: 813019030040 Property Owner: Chulli Corp 920 Grand Hilltop Drive Apopka, FL 32704 Violation: City of Deltona Ordinance, Chapter 42, Article IV, Fire Codes, Ch. 42-186. – Adopted. Florida Fire Prevention Code 8th Edition, NFPA 1, Ch. 1.7.12.10 - No construction work shall proceed until the AHJ has reviewed the plans for compliance with the applicable codes and standards and the applicable permits have been issued Corrective Action: Obtain an electrical permit for the installation of the new electrical panel or renew the expired electrical permit. Captain / Assistant Fire Marshal Samuel Schaller		
Sponsors:			
Indexes:			
Code sections:			
Attachments:			

Date	Ver.	Action By	Action	Result
------	------	-----------	--------	--------