



## Legislation Details

---

**File #:** 15-8855      **Version:** 1  
**Type:** Code Violation      **Status:** New Business  
**File created:** 6/14/2024      **In control:** Special Magistrate  
**On agenda:** 7/2/2024      **Final action:**

**Title:** FIRE-24-037  
Property Address:  
3000 Lake Helen Osteen Road, Deltona, FL 32738  
Parcel ID: 810306000020  
Property Owner:  
Leroy A Young TR  
1999 Young Family Rev Trust  
945 Lincoln Avenue  
Napa, CA 94558-5066

**Violation:**

City of Deltona Ordinance, : Chapter 42, Article IV, Fire Codes, Ch. 42-186. – Adopted.  
Florida Fire Prevention Code 8th Edition, NFPA 1, Ch. 1.7.12.10 - No construction work shall proceed until the AHJ has reviewed the plans for compliance with the applicable codes and standards and the applicable permits have been issued, Ch. 11.1.8 - All panelboard and switchboards, pull boxes, junction boxes, switches, receptacles, and conduit bodies shall be provided with covers compatible with the box or conduit body construction and suitable for the conditions of use.

**Corrective Action:**

Obtain an electrical permit for the installation of the newly provided electrical receptacles and equipment/coolers installed in the produce area. Provided an approved cover for the exterior electrical box.

Captain / Assistant Fire Marshal Samuel Schaller

**Sponsors:**

**Indexes:**

**Code sections:**

**Attachments:**

Date	Ver.	Action By	Action	Result
------	------	-----------	--------	--------