



Legislation Details

File #: 15-8852 **Version:** 1

Type: Code Violation **Status:** New Business

File created: 6/14/2024 **In control:** Special Magistrate

On agenda: 7/2/2024 **Final action:**

Title: FIRE-24-035
 Property Address:
 839 Debarry Avenue, Deltona, FL 32725
 Parcel ID: 813052040050
 Property Owner:
 Coffin Richard H JR Trust
 Ricon Trust
 2070 Creekside Road
 Santa Barbara, CA 93109

Violation:
 City of Deltona Ordinance, Chapter 42, Article IV, Fire Codes, Ch. 42-186. – Adopted.
 Florida Fire Prevention Code 8th Edition, NFPA 1, Ch. 63.9.2.1 - For other than vehicles equipped for
 and using compressed gas as a fuel for propelling the vehicle, an operational permit shall be required
 for liquid carbon dioxide systems in excess of 100 lb (45.4 kg) of carbon dioxide.

Corrective Action:
 Obtain an operational use permit for the liquid carbon dioxide system.

Captain / Assistant Fire Marshal Samuel Schaller

Sponsors:

Indexes:

Code sections:

Attachments:

Date	Ver.	Action By	Action	Result
------	------	-----------	--------	--------