



Legislation Details

File #: 15-8752 **Version:** 1
Type: Code Violation **Status:** New Business
File created: 5/8/2024 **In control:** Special Magistrate
On agenda: 5/22/2024 **Final action:**

Title: FIRE-24-0023
Property Address:
1680 DOyle Road, Deltona, FL 32725
Parcel ID: 813023000040
Property Owner:
Forcam LLC
1680 Doyle Road
Deltona, FL 32725

Violation:
City of Deltona Ordinance, Chapter 42, Article IV, Fire Codes, Ch. 42-186. - Adopted Florida Fire Prevention Code 8th Edition, NFPA 1, Ch. 36.9.2.1, For other than vehicles equipped for and using compressed gas as a fuel for propelling the, vehicle, an operational permit shall be required for liquid carbon dioxide systems in excess of 100 lb (45.4 kg) of carbon dioxide.

Corrective Action:
Obtain an operational use permit for the liquid carbon dioxide system.

Captain / Assistant Fire Marshal Samuel Schaller

Sponsors:

Indexes:

Code sections:

Attachments:

Date	Ver.	Action By	Action	Result
------	------	-----------	--------	--------