



Legislation Details

File #: 15-8753 **Version:** 1

Type: Code Violation **Status:** New Business

File created: 5/8/2024 **In control:** Special Magistrate

On agenda: 5/22/2024 **Final action:**

Title: FIRE-24-0028
 Property Address:
 2090 Saxon Blvd., Deltona, FL 32725
 Parcel ID: 802402000010
 Property Owner:
 HN Saxon
 823 Georgia Ave STE 300
 Chattanooga, TN 37402

Violation:
 City of Deltona Ordinance, Chapter 42, Article IV, Fire Codes, Ch. 42-186. - Adopted Florida Fire Prevention Code 8th Edition, NFPA 1, Ch. 13.1.1 - The AHJ shall have the authority to require that construction documents for all fire protection systems be submitted for review and approval and a permit be issued prior to the installation rehabilitation, or modification. (For additional information concerning construction documents, see Section 1.14.) Further, the AHJ shall have the authority to require that full acceptance tests of the systems be performed in the AHJ's presence prior to final system certification.

Corrective Action:
 Obtain a permit for the installation of the fire alarm cellular communicator and pass all final inspections.

Captain / Assistant Fire Marshal Samuel Schaller

Sponsors:

Indexes:

Code sections:

Attachments:

Date	Ver.	Action By	Action	Result
------	------	-----------	--------	--------