



Legislation Details

File #: 15-8761 **Version:** 1

Type: Code Violation **Status:** Old Business

File created: 5/8/2024 **In control:** Special Magistrate

On agenda: 5/22/2024 **Final action:**

Title: FIRE24-025 MASSEY
 Property Address:
 1800 Elkcarn Blvd., Deltona, FL 32725
 Parcel ID: 813015150170
 Property Owner:
 Marilyn Medina
 1042 Elgrove Drive
 Deltona, FL 32725

Violation:
 City of Deltona Ordinance, : Chapter 42, Article IV, Fire Codes, Ch. 42-186. – Adopted.
 Florida Fire Prevention Code 8th Edition, NFPA 1, Ch. 1.7.12.10 - No construction work shall proceed until the AHJ has reviewed the plans for compliance with the applicable codes and standards and the applicable permits have been issued, Ch. 11.1.5.5 - Extension cords and flexible cords shall not be affixed to structures; extend through walls, ceilings, or floors, or under doors or floor coverings; or be subject to environmental or physical damage.

Corrective action:
 Obtain a building permit for the installation of the wall opening and construction of the small room/what appears to be storage closet inside of the shop. Obtain an electrical permit for the altered electrical work. Remove the extension cords that are extending through the walls and ceiling.

Captain / Assistant Fire Marshal Samuel Schaller

Sponsors:

Indexes:

Code sections:

Attachments:

Date	Ver.	Action By	Action	Result
------	------	-----------	--------	--------