



Legislation Details

**File #:** 15-8760      **Version:** 1

**Type:** Code Violation      **Status:** Old Business

**File created:** 5/8/2024      **In control:** Special Magistrate

**On agenda:** 5/22/2024      **Final action:**

**Title:** FIRE24-016 MASSEY  
 Property Address:  
 1120 Elkcam Blvd., Deltona, FL 32725  
 Parcel ID: 813026010010  
 Property Owner:  
 The Deltona Club/Cahoon Deltona LLC  
 1120 Elkcam Blvd.  
 Deltona, FL 32725-2809

Violation:  
 City of Deltona Ordinance, Chapter 42, Article IV, Fire Codes, Ch. 42-186. – Adopted Florida Fire Prevention Code 8th Edition, NFPA 1, Ch. 1.7.12.10, Ch. 11.1.2.1, Ch. 4.5.8.3, Ch. 14.4.2.1, NFPA 101 Ch. 7.9.2.1.

Corrective action:  
 Obtain a permit for the construction of the wall inside of the pro shop, and all associated electrical work. Obtain a permit for the newly installed electrical conduit in the kitchen, and bring the electrical conduit into compliance with NEC 70, National Electric Code, remove all remaining fire sprinkler heads from the golf cart barn, remove all items obstructing the means of egress in the golf cart barn, and repair the non-functioning exit emergency light combination inside the golf cart barn.

Captain / Assistant Fire Marshal Samuel Schaller

**Sponsors:**

**Indexes:**

**Code sections:**

**Attachments:**

Date	Ver.	Action By	Action	Result
------	------	-----------	--------	--------