


Mission Sent Inc.
 840 Deltona Blvd
 Deltona, FL 32725
 Suite V
 1/8 scale



* - Exit sign / Emergency light
 X - Fire Extinguisher

- Occupant Load Breakdown
 33 persons $20 \text{ sqft/person} = 660 \text{ ft}^2$ required
 per table 7.3.1.2 education
- Proposed Educational Occupancy
- Change of occupancy to Educational
- Type V construction
- We comply with the Florida Fire Prevention Code
- Vacant adjacent tenant
- No proposed/existing exit door locks
- No proposed alterations/modifications
- No proposed electrical, plumbing, mechanical changes
- Fire extinguisher 2x 5lb ABC